



CLIENT AUSTRALIAN DUST SYSTEMS

DUTY

INLET VOLUME 43,550 M<sup>3</sup>/H

PRESSURE 4,000 Pa.

TEMP 20° C

SPEED 1762 R.P.M.

POWER 57.5 KW @ 20° C

MOTOR 90 KW --- 4 POLE --- 415V ---50 CYCLE

FRAME---- D 280 M

|      |          |      |                |
|------|----------|------|----------------|
| REV. |          |      |                |
| A    | 28/11/05 | DATE |                |
| B    | 8/12/05  | DATE |                |
|      |          |      | DUTY REVISED   |
|      |          |      | ORIGINAL ISSUE |
|      |          |      | DESCRIPTION    |

|       |        |         |          |
|-------|--------|---------|----------|
| DRAWN | H.D.P. | DATE    | 28/11/05 |
| SCALE | 1 : 25 | JOB NO. | Q 14.72  |

THIS DRAWING REMAINS THE PROPERTY OF AEROVENT AUSTRALIA AND MUST NOT BE USED OR REPRODUCED WITHOUT PERMISSION.

**AEROVENT AUSTRALIA (Q.L.D.) P.L.**  
 4, PENNANT CRT. BIRKDALE, QLD 4459  
 PHONE (07)3822 1299 FAX (07) 3822 1499

B.C.A.W. - 1000 / 90 CENTRIFUGAL FAN  
 ARRANGEMENT 1 ROTATION ACW 90

| REVISION    | A                | B |
|-------------|------------------|---|
| DRAWING NO. | B.C.A.-1000-9837 |   |

**A3**